

VERIFICATION STATEMENT
FOR WATER SPRAYING FIRE EXTINGUISHING SYSTEM.

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Water spraying fire extinguishing system.
Type designation:	FIREKILL OH-DR1.
Application/context:	Residential and domestic
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	CEN/EN 14972 part 17 and British Standard BS 8458:2015.

Deviations and limitations, if any, are stated on page 2 onwards.

The product / material has been marked: **N141CHS4** on:

Particulars of Vendor and Purchaser

Vendor:	Vid Fire-Kill ApS
Vendor reference:	
Purchaser:	
Purchaser reference:	

Issued at **Fredericia** on **2017-05-26**



for **DNV GL**

This document has been digitally signed and will therefore not have handwritten signatures

Ohmann, Niels
Surveyor



Verification extent and result

Verification extent:

Fire fighting performance test according to CEN/EN 14972 part 17 and British Standard BS 8458:2015.

Verification result/comments:

The VID Fire-Kill low pressure water mist system with VID Fire-Kill OH-DR1 nozzle, installed with 5 x 5 metres spacing and 5 bar water pressure, has been successfully tested to the international approval test CEN/EN 14972 part 17.

Report

The undersigned witnessed successfully testing at Danish Fire Laboratories (DFL) test facilities accredited according to ISO 17025 on 2017-01-12.

Reference is made to DFL test report no. DFL 160704-177 and Fire-Kill OH-DR1 DIOM manual, DOC no. 170309-01-01 dated 2017-03-09.

VERIFICATION STATEMENT
FOR WATER SPRAYING FIRE EXTINGUISHING SYSTEM.

Statement No:
N1422229

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Water spraying fire extinguishing system.
Type designation:	FIREKILL OH-DR1.
Application/context:	Residential and domestic
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	British Standard BS 8458:2015, + prEN 14972-17 Fixed firefighting systems – Residential occupancies, part e): Open room test.

Deviations and limitations, if any, are stated on page 2 onwards.

Particulars of Vendor and Purchaser

Vendor:	Vid Fire-Kill ApS
Vendor reference:	
Purchaser:	
Purchaser reference:	

Issued at **Denmark CMC** on **2021-02-04**



for **DNV GL**

This document has been digitally signed and
will therefore not have handwritten signatures

Lindelof, Kristian
Surveyor



Verification extent and result

Verification extent:

Fire test according to British Standard BS 8458:2015 + prEN 14972-17

Verification result/comments:

The VID FireKill Automatic Low Pressure Watermist Nozzle Model FIREKILL OH-DR1 have successfully been tested according to test method British Standard BS 8458:2015, + prEN 14972-17 Fixed firefighting systems – Residential occupancies, part e): Open room test.

Report

On October 23rd to 26th, 2020 - DNV-GL surveyor has witnessed successful testing of VID Fire-Kill Automatic Low Pressure Water Mist Nozzle Model FIREKILL OH-DR1 at Danish Fire Laboratories (DFL) test facilities, accredited according to ISO 17025.

Reference is made to DFL test report no. DFL 201207-266 dated 2020-12-08.