



# Certificate of Compliance

This certificate is issued for the following:

## Water Mist System

|   |   |
|---|---|
| System Designation:                                     | FIREKILL™ Low Pressure Water Mist System for the Protection of Machinery in Enclosures with Volumes Not Exceeding 9,175 ft <sup>3</sup> (260m <sup>3</sup> )  |
| Design, Installation, Operation and Maintenance Manual: | DIOM FIREKILL™ Total Flooding System Using Model B1/BM1 Open Nozzles For Protection of Machinery in Enclosures Not Exceeding 260 m <sup>3</sup> , Document ID: 200430-01, Revision: 03, Date of Issue: 16-10-2021 |

**Prepared for:**

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

**Manufactured at:**

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

FM Approvals Standard Class: 5560 (January 2021)

Approval Identification: PR455685      Approval Granted: May 31, 2022

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller  
VP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



Member of the FM Global Group

