



# Certificate of Compliance

This certificate is issued for the following:

## Water Mist System

System Designation:	FIREKILL™ Low Pressure Water Mist System for the Protection of Machinery in Enclosures with Volumes Not Exceeding 9,175 ft <sup>3</sup> (260m <sup>3</sup> ) – Model SAS (Stand Alone System)
Design, Installation, Operation and Maintenance Manual:	DIOM FIREKILL™ Total Flooding System Using Model B1/BM1 Open Nozzles for Protection of Machinery in Enclosures Not Exceeding 260 m <sup>3</sup> , Document ID: 200430-01, Revision: 03, Date of Issue: 16-10-2021  DIOM FIREKILL™ Model SAS Stand Alone System, Document ID: 201117-01, Revision: 06, Date of Issue: 04-05-2022

### Prepared for:

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

### Manufactured at:

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

FM Approvals Standard Class: 5560 (January 2021)

Approval Identification: PR458175

Approval Granted: June 1, 2022

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller  
VP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062

