



# Certificate of Compliance

This certificate is issued for the following:

System Designation:	FIREKILL™ Total Flooding System Using Model K6 Open Nozzles for the protection of machinery in enclosures with volumes up to, and including, 162,800 ft <sup>3</sup> (4610 m <sup>3</sup> ) at a maximum height of 39.4 ft (12.0 m)
Design, Installation, Operation and Maintenance Manual:	FIREKILL™ Total Flooding System Using Model K6 Open Nozzles Design, Installation and Maintenance (DIOM) Manual for protection of machinery and combustion turbines in enclosures, Doc No 110629-02-03, dated 21st May 2015

**Prepared for:**

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

**Manufactured at:**

VID FIRE-KILL APS  
SVALBARDVEJ 13  
SVENDBORG  
DK-5700  
DENMARK

FM Approvals Class: 5560

Approval Identification: 3053684      Approval Granted: August 4, 2015

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com) or [www.roofnav.com](http://www.roofnav.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller  
AVP, Manager – Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*