



Certificate of Compliance

This certificate is issued for the following:

System Designation:	FIREKILL™ Total Flooding System Using Model K6 Open Nozzles for the protection of machinery in enclosures with volumes up to, and including, 162,800 ft ³ (4610 m ³) at a maximum height of 39.4 ft (12.0 m)
Design, Installation, Operation and Maintenance Manual:	FIREKILL™ Total Flooding System Using Model K6 Open Nozzles Design, Installation and Maintenance (DIOM) Manual for protection of machinery and combustion turbines in enclosures, Doc No 110629-02-03, dated 21st May 2015

Prepared for:

VID FIRE-KILL APS
SVALBARDVEJ 13
SVENDBORG
DK-5700
DENMARK

Manufactured at:

VID FIRE-KILL APS
SVALBARDVEJ 13
SVENDBORG
DK-5700
DENMARK

FM Approvals Class: 5560

Approval Identification: 3055221 Approval Granted: August 4, 2015

To verify the availability of the Approved product, please refer to www.approvalguide.com or www.roofnav.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
AVP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group