



DET NORSKE VERITAS

**TO WHOM IT MAY CONCERN**

Manufacturer: VID Fire-Kill ApS, Svalbardvej 13, DK-5700 Svendborg, Denmark

Product: Automatic nozzle Model OH-SW

Test of VID Fire-Kill automatic nozzle Model OH-SW  
DFL Fire Test Report No.: 90204-31-2

The test were conducted by Danish Fire Laboratories (DFL) at their premises on February 3 and 4 2009. The laboratory is ISO/IEC 17025 accredited, with accreditation no. 487.

The applied test standard was DFL test standard No.80728-SW rev. 80905 designed in accordance with CEN/TS 14972, Annex B,

And all requirements for test rig, test media, monitoring equipment and execution of the test were in accordance with said standard.

Referring to DFL test report no.: 090204-31, the Model OH-SW nozzle complied with all the standard approval requirements regarding temperature and damage criteria.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.