

VERIFICATION STATEMENT
FOR WATER SPRAYING FIRE EXTINGUISHING SYSTEM

Statement No:
N14202GR

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Water spraying fire extinguishing system
Type designation:	FIREKILL OH-SW2
Application/context:	OH1 risks such as office Spaces and accommodation Areas
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	prEN 14972 Annex A, VdS Firetest Protocol for Water Mist Sidewall Sprinkler Systems

Deviations and limitations, if any, are stated on page 2 onwards.

Particulars of Vendor and Purchaser

Vendor:	Vid Fire-Kill ApS
Vendor reference:	
Purchaser:	
Purchaser reference:	

Issued at **Denmark CMC** on **2020-06-18**



for **DNV GL**

This document has been digitally signed and will therefore not have handwritten signatures

Lindelof, Kristian
Surveyor



Statement No: **N14202GR**

Verification extent and result

Verification extent:

Fire-fighting performance test according to prEN 14972, Annex A, VdS Firetest Protocol for Water Mist Sidewall Sprinkler Systems as of: 04/2016(Rev01).

Verification result/comments:

The VID Fire-Kill low pressure water mist system with the nozzle OH-SW2 installed with 6 x 6m spacing has been successfully tested to the international approval test prEn14972, Annex A, VdS firetest protocol for water mist sidewall sprinkler systems with 5m ceiling height.

Report

The undersigned witnessed successfully testing at Danish Fire Laboratories(DFL), test facility accredited to ISO 17025, on 2020-05-06 and 2020-06-03. Reference is made to DFL test report no. 200612-254-1, component test report no. 200612-254-2 of the OH-SW2 nozzle and FireKill OH-SW2 DIOM Manual no. 200527-01-01