

VERIFICATION STATEMENT
FOR WATER SPRAYING FIRE EXTINGUISHING SYSTEM

Statement No:
N141AS73
Rev.01

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Water spraying fire extinguishing system
Type designation:	FIREKILL OH-UPR
Application/context:	Car Park Garages
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	CENTS 14972 Annex AX Fire test protocol for car park garages – Revision by Vds with track changes

Deviations and limitations, if any, are stated on page 2 onwards.

The product / material has been marked: N141AS73 on:

Particulars of Vendor and Purchaser

Vendor:	Vid Fire-Kill ApS
Vendor reference:	
Purchaser:	
Purchaser reference:	

Issued at **Fredericia** on **2016-09-05**



for **DNV GL**

This document has been digitally signed and will therefore not have handwritten signatures

Lindelof, Kristian
Surveyor

Except for any liability caused by DNV GL's gross negligence or wilful misconduct, DNV GL's maximum cumulative liability arising out of or related to the use of or reliance on this document shall be limited to USD 300 000.

Statement No: **N141AS73**
Rev.01

Verification extent and result

Verification extent:

Fire-fighting performance test according to CENTS 14972 Annex AX Fire test protocol for Car Park Garages – Revision by Vds with track changes

Verification result/comments:

The VID Fire-Kill low pressure water mist system with VID Fire-Kill OH-UPR nozzle, installed with 4m x 4m spacing has been successfully tested to the international approval test CENTS 14972 Annex AX Fire Test Protocol for Car Park Garages with 3 m. ceiling height.

Report

The undersigned witnessed successfully testing at Danish Fire Laboratories (DFL), test facility accredited according to ISO 17025, on 2016-06-14 and 2016-06-21

Reference is made to DFL test report no. 160214-166, Component Test Report No. 110415-5 of the OH-nozzle and FIREKILL OH-UPR DIOM Manual, DOC No. 160809-03-01