

VERIFICATION STATEMENT
FOR WATER SPRAYING FIRE EXTINGUISHING SYSTEM

Statement No:
N141CU83
Rev.01

Valid for products not subject to DNV GL classification requirements.

Particulars of Product

Product Name:	Water spraying fire extinguishing system
Type designation:	FIREKILL OH-VSO
Application/context:	Public Spaces
ID/Serial/Tag no:	N.A.
The product is intended for:	STOCK
Requirements are based on:	FM 5560 Appendix G Open Space

Deviations and limitations, if any, are stated on page 2 onwards.

The product / material has been marked: N141CU83 on:

Particulars of Vendor and Purchaser

Vendor:	Vid Fire-Kill ApS
Vendor reference:	
Purchaser:	
Purchaser reference:	

Issued at **Fredericia** on **2017-02-01**



for **DNV GL**

This document has been digitally signed and will therefore not have handwritten signatures

Lindelof, Kristian
Surveyor



Statement No: **N141CU83**
Rev.01

Verification extent and result

Verification extent:

Fire-fighting performance test according to FM 5560 Appendix G Open Space

Verification result/comments:

The VID Fire-Kill OH-VSO nozzle, designed by VID, Vision Idea Design, Svendborg, Denmark, have successfully been tested according to FM 5560 Appendix G Open Space, with 6m ceiling height, nozzle spacing 4,5m and 8 bar water pressure, all in accordance with DIOM 140605-03-03.

Report

The undersigned witnessed successfully testing at Danish Fire Laboratories (DFL), test facility accredited according to ISO 17025, on 2016-12-20

Reference is made to DFL test report no. 160627-176 and FM Test Reports Nos. 3041497, 3050321, 3052545 and 3053358