


Product Data Sheet Zone Control Valve Assembly Standard solenoid valve **TUNPROTEC®**

FIXED FIRE FIGHTING SYSTEMS

For road and rail tunnels






Description

The TUNPROTEC Model Tunprotec C-M-80-80-S Zone Control Valve assembly is a factoryassembled and -tested fire zone control valve designed for implementation in TUNPROTEC systems.

As fire zone control valve, the Model Tunprotec C-M-80-50-S Zone Control Valve has been designed to hydraulically control the flow of water from the wet supply system to the dry TUNPROTEC N-Pipe low pressure water mist system.

The valve assembly includes:

- 1. Service Valve (Upstream)
- 2. Tamper switch (Service Valve position)
- 3. Zone control valve
- 4. DIN control box (optional)
- 5. Drain- and test valve
- 6. High-capacity filter
- 7. Tamper switch (Test Valve position)
- 8. Service- and test valve Downstream
- 9. Pressure switch
- 10. Solenoid Valve
- 11. Tamper switch (Drain- and test valve)



The Model Tunprotec C-M-80-50-S features small outer dimensions, robust and reliable components, and the ability to remotely activate the zone control valve and allowing the fire zone control valve to be monitored remotely through relay switches.

The fire zone control valve is shipped fully assembled and can be easily installed into protected areas or into cabinets.

Application

The Model Tunprotec C-M-80-50-S Zone Control Valve had been designed and tested for installation.

in infrastructure tunnels of unlimited length. Among approved applications are road, train, metro, cable, conveyor, mining, and pedestrian tunnels.

Dimensions: 1018 x 571 x 295 mm (HxWxD) Max. working 25 bars pressure Kv-value 1800 I/min/√(bar) Material AISI 316 1x DN80 Flanged (Inlet) Hvdraulic 1x DN50 Flanged (outlet) connections 1x 1" BSP (Drain) Solenoid valve: 24 VDC, Electrical Tamper Switch: 1NO+1NC, connections: Pressure indicator: 24V, NO/NC, Sales and order TPT-10938 / C-M-80-50-S number

General Description

Approvals

The zone control value (3) has been approved with $\begin{bmatrix} n \\ n \end{bmatrix}$

a mean time to failure (MTTF) of 150 years and is successfully component tested by FM Approvals.

TUNPROTEC system is holding IBS Institute für Brandschutztechnik und Sicherheitsforschung approval. The zone control valve can optionally be supplied with SIL 2 compliant activation.



Installation

Once received the Zone Control Valve shall be stored under safe conditions, protected from harmful materials and physical damage.


Prior to installation of the Model Tunprotec C-M-80-50-S Zone Control Valve, the pipe system to be connected shall be flushed and rinsed, and the area in which the valve assembly is to be installed into, shall be checked to not interfere with the valve assembly and its functions.

When installing Model Tunprotec C-M-80-50-S Zone Control Valve, the valve assembly shall first be fixed in place using approved brackets or pipe-hangers and then connecting to the flanged inlet and outlet connections, after which the threaded drain connections can be connected to a general drain system and the control box can be connected to detection and control systems.

NOTE: The complete piping system upstream to the valve assembly including the pilot chamber shall be completely water filled prior to starting any pump.

NOTE: The fire pump shall always be stopped prior to closing the Zone Control Valve.

Dimensions



Contact

For more information on the Model Tunprotec-C-M-80-50-S, and the TUNPROTEC system and its components, kindly contact the TUNPROTEC sales team at <u>tunprotec@vidfirekill.com</u>

Disclaimer: VID Fire-Kill APS is not responsible for any errors or omissions, or for the results obtained from the use of this information. All information in this document is provided "as is", with no guarantee of completeness, accuracy, functionality, timeliness or of the results obtained from the use of this information.

VID Fire Kill ApS Svalbardvej 13, DK-5700 Svendborg Denmark Phone: +45 62 62 10 24 E-mail: sales@vidfirekill.com Internet: www.vidfirekillcom Page 3 of 3