



Approval Certificate for Protection of OH1 risks

Certificate No.: 322091501-3

Certificate date: 28th August 2022

Engineer: Wolfgang REICHÖR / SchD

Extension: 812

SYSTEM MANUFACTURER: VID FIRE-KILL APS, Svalbardvej 13, DK-5700 Svenborg

SYSTEM: Low Pressure Watermist System for OH1 risks

SCOPE OF CERTIFICATE: Automatic Low-Pressure Water Mist System system is
Nozzle: OH-SW2
Applications: Offices, Public areas of low fire load, hotel rooms, rooms in hospitals, care homes, schools, flats, accommodation areas as well as any other comparable risks.

APPLICABLE STANDARDS: EN 14972



Duplicating extracts from this report is permissible only with the consent of IBS.



BASIS OF CERTIFICATE:

Test Reports; Full Scale Fire Test

- DFL test report no.:200612-254-1

APPROVAL VALIDITY:

Effective from key date for prolongation of the
certificate (28th August 2022) for two years until
28th August 2024

**INSTALLATION
INSTRUCTIONS:**

- DIOM CEN EN 14972
NO.:210125-01-J OH-CEN DIOM Rev. J
28-08-2022

**IBS – INSTITUT FÜR BRANDSCHUTZTECHNIK UND
SICHERHEITSFORSCHUNG GESELLSCHAFT M.B.H.**

Wolfgang REICHÖR
Technical Officer

ING. Georg Dammayr
Division Manager

Dipl. Ing. (FH) Josef Huber
CEO