



# Approval Certificate for Protection of OH2 risks

**Certificate No.:** 322091501-4

Certificate date: 28th August 2022

Engineer: Wolfgang REICHÖR / SchD

Extension: 812

**SYSTEM MANUFACTURER:** VID FIRE-KILL APS, Svalbardvej 13, DK-5700 Svenborg

**SYSTEM:** Low Pressure Watermist System for OH2 risks

**SCOPE OF CERTIFICATE:** Automatic Low-Pressure Water Mist System system is  
**Nozzle: OH-UPR**  
Applications: Non-automatic, fully enclosed garages,  
underground garages, car park garages

**APPLICABLE STANDARDS:** EN 14972



Duplicating extracts from this report is permissible only with the consent of IBS.



**BASIS OF CERTIFICATE:**

Test Reports; Full Scale Fire Test

- DFL test report no.:160214-166

**APPROVAL VALIDITY:**

Effective from key date for prolongation of the  
certificate (28<sup>th</sup> August 2022) for two years until  
**28<sup>th</sup> August 2024**

**INSTALLATION  
INSTRUCTIONS:**

- DIOM CEN EN 14972  
NO.:210125-01-J OH-CEN DIOM Rev. J  
28-08-2022

**IBS – INSTITUT FÜR BRANDSCHUTZTECHNIK UND  
SICHERHEITSFORSCHUNG GESELLSCHAFT M.B.H.**

Wolfgang REICHÖR  
Technical Officer

ING. Georg Dammayr  
Division Manager

Dipl. Ing. (FH) Josef Huber  
CEO