

Statement of Compliance
Pressure equipment directive (PED) 2014/68/EC
Low voltage directive (LVD) 2014/35/EU



Manufacturer	: VID Fire-Kill ApS
Address	Svalbardvej 13
	DK-5700 Svendborg
	Denmark

Description	: Filter
-------------	----------

Model	Part number
Filter F-50-50 Basic 1000 micron	F-10800
Filter F-80-80 Basic 1000 micron	F-10801
Filter F-50-50 monitoring 1000 micron	F-10804
Filter F-80-80 monitoring 1000 micron	F-10805
Filter F-50-50 marine version standard 320 micron	F-10808
Filter F-80-80 marine version standard 320 micron	F-10809
Filter F-50-50 marine version monitoring 320 micron	F-10810
Filter F-80-80 marine version monitoring 320 micron	F-10811

VID Fire-Kill ApS confirms that the products listed above, defined under the Pressure Equipment Directive (PED) 2014/68/EC as 'Pressure Accessories', are below or equal to the limits set out in points (a), (b) and (c) of paragraph 1 and in paragraph 2 respectively and have been designed and manufactured in accordance with Sound Engineering Practice (SEP) Article 4, Paragraph 3. As such, CE marking must not be applied.

Further VID Fire-Kill ApS confirms that the products listed above is not within the requirements for the Low Voltage Directive (LVD) 2014/35/EU as the 24 VDC operating input voltage defined in the above-mentioned directive is below the requirement which is 75 V to 1500 V for direct current.

Svendborg 2024-02-22

Lars Elsrud
CTO