

Description

The FIRE KILLTM Model F is a patented system of compact high capacity in-line style filters, for protection of small openings and orifices and small capacity filters and clearances against clogging, and for protection against abrasive wear of internal surfaces in pipe systems transporting liquids.

The Model F can be supplied with a unique feature of either visual or electronic alarm for when it's time to clean/rinse it.

The Model F filters have been tested with full contamination load in water to the International Maritime Organization (IMO) clogging test standard for water mist systems MSC 1165 and IMO MSC 265(84).

The Model F is to be used with all VID Fire-Kill open and automatic nozzles to ensure that no clogging will occur.

Application

- Low pressure water mist systems
- Water spray systems
- Heating and Industrial pipe systems

Technical data

Specification		
Pressure loss	DN 50 - 0.1 bar (0-500 I/min)	
	DN80 - 0.1 bar (0-2000 l/min)	
Working Pressure	16 bar	
Test pressure	24 bar	
Material	AISI 316	
Connection	Flanged DIN PN16	
Filter size	310 micron	
Weight Kg	DN 50 - 8,80 Kg	
	DN 80 - 12,50 Kg	
Visual and electric "rinse" alarm		
Standard alarm setting	Pressure loss above 0,5 bar	
Optional setting	0,1 bar to 5 bar	
Specification switch		
Max switching voltage	250 VAC/24 VDC	
Max load	60 W	
Max current	1 A	
Terminals	1 – NC	
	2 – NO	
	3-C	



Date of first issue: 10-01-2018 Date of revision: 05-09-2023




Maintenance

Model F filters are designed for easy service due to the flanged style installation and with the unique feature of either visual or electronic alarm for when it's time to clean it, due to the unique monitoring system where the inlet and outlet pressure is measured.

Dimension

	DN 50	DN 80
H1	204 mm	284 mm
H2	220 mm	300 mm
OD	ø 165 mm	ø 200 mm
L1	170 mm	238 mm
øK	ø 125 mm	ø 160 mm
øΑ	4 x ø 18 mm	8 x ø 18 mm
øG	ø 66 mm	ø 66 mm



Contact

For further information on FIREKILL™ products, please contact our sales department at Sales@vidfirekill.com

VID Fire-Kill APS is not responsible for any errors or omissions, or for the results obtained from the use of this information. All information in this document is provided "as is", with no guarantee of completeness, accuracy, functionality, timeliness or of the results obtained from the use of this information.

Date of first issue: 10-01-2018 Date of revision: 05-09-2023