

**Statement of Compliance**  
**Pressure equipment directive (PED) 2014/68/EC**  
**Low voltage directive (LVD) 2014/35/EU**



Manufacturer	: VID Fire-Kill ApS
Address	Svalbardvej 13
	DK-5700 Svendborg
	Denmark

Description	: Deluge and pre-action valves Wet alarm valves
-------------	--

Model	Part number	Model	Part number
C-EL-B-25	CEL-13100	C-EL-B-25 Impulse	CEL-13101
C-EL-50-50	CEL-10401	C-EL-80-80	CEL-10403
C-EL-50-50 Impulse	CEL-10402	C-EL-80-80 Impulse	CEL-10404
C-EL-2"-2"	CEL-10405	C-EL-3"-3"	CEL-10425
C-EL-2"-2" Impulse	CEL-10406	C-EL-3"-3" Impulse	CEL-10426
C-EL-B-50-50	CELB-13102	C-EL-B-80-80	CELB-13106
C-EL-B-50-50 Impulse	CELB-13103	C-EL-B-80-80 Impulse	CELB-13107
C-EL-PA-50-50	CELPA-10440	C-EL-PA-80-80	CELPA-10442
C-EL-PA-50-50 Impulse	CELPA-10441	C-EL-PA-80-80 Impulse	CELPA-10443
C-EL-PA-2"-2"	CELPA-10444	C-EL-PA-3"-3"	CELPA-10446
C-EL-PA-2"-2" Impulse	CELPA-10445	C-EL-PA-3"-3" Impulse	CELPA-10447
C-EL-B-PA-50-50	CELB-PA-13200	C-EL-B-PA-80-80	CELB-PA-13204
C-EL-B-PA-50-50 Impulse	CELB-PA-13201	C-EL-B-PA-80-80 Impulse	CELB-PA-13205
WAC-DN40-Type A	WAC-10408	WAC-DN50-Type A	WAC-10407
WAC-DN40-Type B	WAC-10439	WAC-DN50-Type B	WAC-10438

VID Fire-Kill ApS confirms that the products listed above, defined under the Pressure Equipment Directive (PED) 2014/68/EC as 'Pressure Accessories', are below or equal to the limits set out in points (a), (b) and (c) of paragraph 1 and in paragraph 2 respectively and have been designed and manufactured in accordance with Sound Engineering Practice (SEP) Article 4, Paragraph 3. As such, CE marking must not be applied.

Further VID Fire-Kill ApS confirms that the products listed above is not within the requirements for the Low Voltage Directive (LVD) 2014/35/EU as the 24 VDC operating input voltage defined in the above-mentioned directive is below the requirement which is 75 V to 1500 V for direct current.

Svendborg 2024-01-10

Lars Elsrud  
 CTO